



Product Service

CERTIFICATE

No. Z2 111130 0004 Rev. 02

Holder of Certificate: **MYLIGHT SYSTEMS S.A.S.**

1609 Avenue Henri Schneider
ZAC des Gaulnes
69330 Jonage
FRANCE

Certification Mark:



Product:

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Mono-crystalline Silicon Hetero-junction Photovoltaic module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 701262206102-02

Valid until: 2024-03-30

Date, 2023-10-13

(Zhulin Zhang)

CERTIFICATE

No. Z2 111130 0004 Rev. 02

Model(s):

Framed:

166 cell modules:

MYL-B144DSxxx (xxx=440 to 500 in step of 5)
MYL-B132DSxxx (xxx=405 to 455 in step of 5)
MYL-B120DSxxx (xxx=365 to 415 in step of 5)
MYL-B144DSNxxx (xxx=440 to 480 in step of 5)
MYL-B132DSNxxx (xxx=405 to 440 in step of 5)
MYL-B120DSNxxx (xxx=365 to 400 in step of 5)
MYL-B156DSBxxx (xxx=490 to 520 in step of 5)
MYL-B144DSBxxx (xxx=450 to 480 in step of 5)
MYL-B132DSBxxx (xxx=410 to 440 in step of 5)
MYL-B120DSBxxx (xxx=375 to 400 in step of 5)
MYL-B156DSNxxx (xxx=490 to 520 in step of 5)
MYL-B156DSxxx (xxx=490 to 520 in step of 5)
MYL-S120DSBxxx (xxx=370 to 400 in step of 5)
MYL-S144DSxxx (xxx=450 to 480 in step of 5)
MYL-S132DSxxx (xxx=410 to 440 in step of 5)
MYL-S120DSxxx (xxx=375 to 400 in step of 5)

210 cell modules:

MYL-210-B132DSxxx (xxx=640 to 720 in step of 5)
MYL-210-B120DSxxx (xxx=590 to 650 in step of 5)
MYL-210-B110DSxxx (xxx=540 to 590 in step of 5)

182 cell modules:

MYL-182-B144DSxxx (xxx=550 to 600 in step of 5)
MYL-182-B108DSxxx (xxx=410 to 450 in step of 5)
MYL-182-S108DSBxxx (xxx=425 to 445 in step of 5)
MYL-182-B108DSNxxx (xxx=420 to 440 in step of 5)
MYL-182-B108DSBxxx (xxx=420 to 440 in step of 5)

Frameless:

MYL-B144DNxxx (xxx=440 to 500 in step of 5)
MYL-B132DNxxx (xxx=405 to 455 in step of 5)
MYL-B120DNxxx (xxx=365 to 415 in step of 5)
MYL-B144DNNxxx (xxx=440 to 480 in step of 5)
MYL-B132DNNxxx (xxx=405 to 440 in step of 5)
MYL-B120DNNxxx (xxx=365 to 400 in step of 5)
MYL-B96DNNxxx (xxx=295 to 320 in step of 5)

xxx stands for rated output power at STC

The corresponding BSTC power range as follows:

All electrical data is shown as relative to this test conditions:

front side irradiance 1000 W/m², backside irradiance 135 W/m², 25 °C, AM 1.5

Framed:

166 cell modules:

MYL-B144DSxxx (BSTC Power range: 490W to 550W in step of 5)
MYL-B132DSxxx (BSTC Power range: 450W to 500W in step of 5)
MYL-B120DSxxx (BSTC Power range: 405W to 455W in step of 5)
MYL-B144DSNxxx (BSTC Power range: 495W to 535W in step of 5)
MYL-B132DSNxxx (BSTC Power range: 455W to 490W in step of 5)
MYL-B120DSNxxx (BSTC Power range: 410W to 445W in step of 5)
MYL-B156DSBxxx (BSTC Power range: 540W to 570W in step of 5)
MYL-B144DSBxxx (BSTC Power range: 495W to 525W in step of 5)
MYL-B132DSBxxx (BSTC Power range: 450W to 480W in step of 5)
MYL-B120DSBxxx (BSTC Power range: 410W to 435W in step of 5)
MYL-B156DSNxxx (BSTC Power range: 545W to 575W in step of 5)
MYL-B156DSxxx (BSTC Power range: 540W to 570W in step of 5)

210 cell modules:

MYL-210-B132DSxxx (BSTC Power range: 710W to 790W in step of 5)
MYL-210-B120DSxxx (BSTC Power range: 655W to 715W in step of 5)
MYL-210-B110DSxxx (BSTC Power range: 600W to 650W in step of 5)

182 cell modules:

MYL-182-B144DSxxx (BSTC Power range: 610W to 660W in step of 5)
MYL-182-B108DSxxx (BSTC Power range: 455W to 495W in step of 5)
MYL-182-B108DSNxxx (BSTC Power range: 470W to 490W in step of 5)
MYL-182-B108DSBxxx (BSTC Power range: 465W to 485W in step of 5)



CERTIFICATE

No. Z2 111130 0004 Rev. 02

Frameless:

- MYL-B144DNxxx (BSTC Power range: 490W to 550W in step of 5)
- MYL-B132DNxxx (BSTC Power range: 450W to 500W in step of 5)
- MYL-B120DNxxx (BSTC Power range: 405W to 455W in step of 5)
- MYL-B144DNNxxx (BSTC Power range: 495W to 535W in step of 5)
- MYL-B132DNNxxx (BSTC Power range: 455W to 490W in step of 5)
- MYL-B120DNNxxx (BSTC Power range: 410W to 445W in step of 5)
- MYL-B96DNNxxx (BSTC Power range: 325W to 350W in step of 5)

Parameters:

Fire Safety Class:	Class C according to UL790
Max. system voltage:	1500V DC
Safety Class:	Class II
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute. No. 10 West Kaifa Road, Yangzhou, 225009 Jiangsu, P. R. China.
Construction:	Framed or Frameless, with Junction box, cable and connector.

Tested according to:

- IEC 61215-1:2016
- IEC 61215-1-1:2016
- IEC 61215-2:2016
- IEC 61730-1:2016
- IEC 61730-2:2016
- EN 61215-1:2016
- EN 61215-1-1:2016
- EN 61215-2:2017
- EN IEC 61730-1:2018
- EN IEC 61730-1:2018/AC:2018-06
- EN IEC 61730-2:2018
- EN IEC 61730-2:2018/AC:2018-06